

**ADA-Required Inspection items for Car Quest Sites:**

Service Call ID #: 0403-1595

Date: 03/11/04

Address/City/State: 23635 El Toro Rd., Suite B, Lake Forest, CA

Technician: Bob Awalt

Item #:	ITEM:	ADA Requirements:	STANDARD:	ACTUAL:
1	Accessible Parking spaces	There shall be enough accessible parking spaces as per ADA standard	1-25 = 1, 26-50 = 2, 51-75 = 3, 76-100 = 4, 101-150 = 5, 151-200 = 6, 201-300 = 7, 301-400 = 8, 401-500 = 9	<p><b>If a problem is noted take a photograph</b></p> <input type="checkbox"/> Okay <input type="checkbox"/> Not applicable <input checked="" type="checkbox"/> Non-compliant* *Description: None noted in front of store <input checked="" type="checkbox"/> Photo taken of non-compliance Photo#2
2	Accessible Sites and Exterior Facilities	At least one accessible route must be provided within the boundaries of the site from public transportation stops, parking spaces, loading zones, and public streets and sidewalks to an accessible building entrance		<input checked="" type="checkbox"/> Okay <input type="checkbox"/> Not applicable <input type="checkbox"/> Non-compliant* *Description: <input type="checkbox"/> Photo taken of non-compliance Photo#
3	Adjacent accessible spaces	Access aisles adjacent to accessible spaces shall be 60" minimum in width		<input type="checkbox"/> Okay <input type="checkbox"/> Not applicable <input checked="" type="checkbox"/> Non-compliant* *Description: None noted but 1 stall could be converted next to curb ramp <input checked="" type="checkbox"/> Photo taken of non-compliance Photo#3
4	Curb Ramps	Ramps must have a slope that does NOT exceed 1:12, and be a minimum of 36" wide (not including curb flares)		<input checked="" type="checkbox"/> Okay <input type="checkbox"/> Not applicable <input type="checkbox"/> Non-compliant* *Description: <input type="checkbox"/> Photo taken of non-compliance Photo#
5	Ramps	Ramps must have a slope that does NOT exceed 1:12, and be a minimum of 36" wide.		<input checked="" type="checkbox"/> Okay <input type="checkbox"/> Not applicable <input type="checkbox"/> Non-compliant* *Description: <input type="checkbox"/> Photo taken of non-compliance Photo#
6	Accessible route to Parking Spaces	Accessible parking spaces shall be located on the shortest accessible route of travel from the parking lot to the accessible entranceway. Accessible parking spaces shall be a minimum of 96" wide. Parking access aisles shall be part of an accessible route to the building or facility entrance.		<input type="checkbox"/> Okay <input type="checkbox"/> Not applicable <input type="checkbox"/> Non-compliant* *Description: <input type="checkbox"/> Photo taken of non-compliance Photo#







1) Front of building.



2)



3)



4)



5)



6)